

LOCATION 924 Crowders Woods Dr. CITY Gastonia
BETWEEN Hope Marian Ct. STREET & Dead End. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	108'	10-21-02		
MAIN TO PROP LINE	5/8"	P	43'	"		
PROP LINE TO BLDG	5/8"	P	65'	"		

ENTERS 924 BRANCHED INTO 0
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 101' south of

center of Hope Marian Ct.
PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY D. Woody

MAIN-SIZE 4" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2002

DEPTH 3' FT 0" IN LOCATION 19' West of center of Crowders Woods Dr.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 3/2012

REMARKS New Plastic service

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	E	<u>service</u>

