

LOCATION 1133 Crowder Woods Dr. CITY Atlanta
 BETWEEN Carson Rd. STREET & Janner Ct. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>Plastic</u>	<u>65'</u>	<u>8-26-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>Plastic</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>Plastic</u>	<u>55'</u>			

ENTERS 1133 BRANCHED INTO 0
 TAP SIZE 3/4 PRESSURE 60 PSI INCHES W C LOCATION 25.3' N of C of Carson Rd.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL
 MAIN-SIZE 4" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2002
 DEPTH 5 FT 0 IN LOCATION 18' W of C of Crowders Woods Dr.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>