

LOCATION 2967 DAFFODIL CT CITY Easton
BETWEEN Herpman Rd STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>67</u>			
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>5</u>	<u>6-23-99</u>		
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>67</u>			

ENTERS 2967 BRANCHED INTO 0
TAP SIZE 1/2 PRESSURE 100 PSI INCHES W.C. LOCATION


PRESSURE TEST 100 PSI FOR 1/4 HRS BY EP

MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3 FT 0 IN LOCATION

"A" P/S READING P TOTAL ANODES 1# 17# LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>Alston</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	