

LOCATION 2991 Daffodil Ct. CITY Gastonia
BETWEEN Hoffman STREET & Dead end STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>83'</u>	<u>9-20-99</u>		
MAIN TO PROP LINE	<u>1"</u>	<u>1"</u>	<u>11'</u>			
PROP LINE TO BLDG	<u>1"</u>	<u>1"</u>	<u>72'</u>			

ENTERS 2991 BRANCHED INTO —
TAP SIZE 1/2 PRESSURE _____ PSI _____ INCHES W C LOCATION 20' W. of CM


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY JP Daffodil

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	