

LOCATION 401 DALE AVE.CITY GASTONIABETWEEN DALE AVESTREET & W RUBY

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>8'</u>		<u>TIED OVER</u>	<u>97' EXISTING</u>
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>4'</u>		<u>3/4 PLASTIC</u>	<u>TO 2" PLASTIC</u>
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>30'</u>		<u>MAIN</u>	<u>2-24-98</u>

ENTERS: 401


BRANCHED INTO

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W C LOCATION 17' FROM W 1/2 OF OAKWOOD AVE.PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY BBMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997DEPTH 3 FT 0 IN LOCATION 92' SOUTH 1/2 OF DALE AVE."A" P/S READING PLASTIC

TOTAL ANODES 1# _____ 17# _____

L.R. # _____

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY