

LOCATION 401 Dole Ave CITY Lorton

BETWEEN Oakwood STREET & Crescent STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	102	8-18-84		
MAIN TO PROP. LINE	3/4	"	12			
PROP. LINE TO BLDG.	3/4	"	90			

ENTERS: 401 BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE \_\_\_\_\_ P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION W of C of St


PRESSURE TEST: @ \_\_\_\_\_ psi For \_\_\_\_\_ Hrs. By Bennett

MAIN-SIZE 1 1/4 C.I. \_\_\_\_\_ BARE STEEL ☒ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1951

DEPTH: 2 Ft. 4 In. LOCATION 13' W of C of Oakwood

"A" P/S READING 0.35 TOTAL ANODES 1# \_\_\_\_\_ 17# 1 L.R. # 00338677

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY