

LOCATION 419 Dale AveCITY GastoniaBETWEEN CrescentSTREET & 321

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<del>100</del> Plastic	<u>109</u>	<u>2-21-98</u>		<u>2-21-98</u>
MAIN TO PROP. LINE	<u>3/4</u>	Plastic	<u>42</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	Plastic	<u>67</u>			


ENTERS:

- BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 224 South ofDalePRESSURE TEST: @ 100 psi For 1/4 Hrs. By K HayesMAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION 17 West of Crescent

"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY