

LOCATION 420 DALE AVECITY GASTONIABETWEEN YORK RDSTREET & CRESCENT AVE

STREET


	SIZE	TYPE	420 LENGTH	1124	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>94'</u>		<u>Tied over</u>	<u>3-2-98</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>38'</u>		<u>47' 3/4 plastic</u>		
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>36'</u>		<u>Service to 1124 S York Rd with 38' New 3/4 plastic</u>		

ENTERS: 420 DALE AVEBRANCHED INTO: 1124 S. York RdTAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 139' EAST FROM C/OF YORK RDPRESSURE TEST @ 100 PSI FOR 1/4 HRS BY BBMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997DEPTH. 3 FT 0 IN LOCATION 24' SOUTH FROM C/OF DALE AVE"A" P/S READING PLASTIC

TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_

L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>RI SER</u>	<u>PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY