

LOCATION 922 Dallas-Bossermer city RdCITY GastoniaBETWEEN Hollisrest StSTREET & Vanderburg Rd

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	$\frac{3}{4}$	P	114'	01-05-96		
MAIN TO PROP. LINE	"	"	40'			
PROP. LINE TO BLDG.	"	"	74'			

ENTERS: 922

BRANCHED INTO:

TAP SIZE:  $\frac{1}{2}$ 


PRESSURE

P.S.I.

INCHES W.C.

LOCATION 15' E. of C ofDallas-Bossermer RdPRESSURE TEST: @ 100 psi For 1/4 Hrs. By SPMAIN-SIZE 4" C.I. ☐ BARE STEEL ☐ COATED STEEL ☒ PLASTIC ☐ YEAR INSTALLED 1962DEPTH: 3 Ft. 0 In. LOCATION"A" P/S READING 1.30 TOTAL ANODES 1# 17 # 1 L.R. # 1

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading &amp; Location

Lead

Volts

P/S Pipeline Lead - Red  
New Service

R

P

P/S Pipeline Lead - White  
Existing Main

E