

LOCATION 4302 Derrydown Lw. CITY Gastonia
BETWEEN _____ STREET & _____ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	69'	12-16-02		
MAIN TO PROP LINE	5/8"	P	12'			
PROP LINE TO BLDG	5/8"	P	57'			

ENTERS 4302 BRANCHED INTO _____
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 12' S. of center of Derrydown Lw.

PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY S.H.
MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED _____
DEPTH 3 FT 0 IN LOCATION 37' 6" of center of Put-de-Sac

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 365040

REMARKS _____

