

LOCATION 601 Dartmouth CITY Costa Mesa  
BETWEEN Fairfield Dr. STREET & Fairfield Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>3'</u>		<u>Tied over 1/4" of</u>	
MAIN TO PROP. LINE	<u>3/4</u>			<u>6-11-94</u>	<u>Ext 3/4 Plastic to</u>	
PROP. LINE TO BLDG.					<u>Ext 2" Plastic main</u>	

ENTERS: 601 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. \_\_\_\_\_ LOCATION \_\_\_\_\_


PRESSURE TEST: @ 100 psi For 1 1/2 Hrs. By ED

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION \_\_\_\_\_

"A" P/S READING P TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: \_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY