

LOCATION 607 Dartmouth dr.CITY BostonBETWEEN Fairfield dr.

STREET &

STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------|-----------|----------------|----------------------|-------------------|
| MAIN TO BLDG. | <u>3/4</u> | <u>P</u> | <u>3'</u> | <u>6-18-94</u> | <u>fail over 75'</u> | <u>of 3/4 C/w</u> |
| MAIN TO PROP. LINE | | | | | <u>serv. to Exl</u> | <u>2" P. main</u> |
| PROP. LINE TO BLDG. | | | | | | |

ENTERS: 607BRANCHED INTO: -TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 18' W of C of
Dartmouth drPRESSURE TEST: @ 100 psiFor 1/4 Hrs.By EPMAIN-SIZE 2"

C.I.

BARE STEEL

COATED STEEL


PLASTIC ☒YEAR INSTALLED 1983DEPTH: 3Ft. 0 In.

LOCATION

"A" P/S READING

TOTAL ANODES 1* 1 17* -L.R. # -

REMARKS:



Test Station

ENG. DEPT. USE ONLY

| Reading & Location | Lead | Volts |
|--|-----------|-------------|
| P/S Pipeline Lead - Red New Service | <u>OR</u> | <u>1.50</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |