

LOCATION 613 Dartmouth Dr CITY Lebanon
BETWEEN Fairfield Dr. STREET & Fairfield Dr. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------------|-----------|----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>PLASTIC</u> | <u>82</u> | <u>6-18-94</u> | | |
| MAIN TO PROP. LINE | <u>3/4</u> | <u>"</u> | <u>5</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4</u> | <u>"</u> | <u>78</u> | | | |

ENTERS: 613 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Spideephouse

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By Bennett


MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 2 Ft. 6 In. LOCATION 20' W of flt

"A" P/S READING _____ TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS:

~~Bar~~ Main Replacement
Program



| Test Station | | |
|--|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY