

LOCATION 308 E. DAVIDSON CITY CASTONIA

BETWEEN HANOVER STREET & MARIETTA STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>125</u>			
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>30'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>35'</u>			<u>4/9/99</u>

ENTERS 308 BRANCHED INTO 0

TAP SIZE 3/4 IN. PRESSURE 60 PSI INCHES WC LOCATION

PRESSURE TEST 100 PSI FOR 1/4 HRS BY EP

MAIN SIZE 6" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1953

DEPTH 2 FT 0 IN LOCATION

"A" P/S READING 0.8 TOTAL ANODES 1# 17 LR #

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>1.52</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	<u> </u>

