

LOCATION 804 E. DavidsonCITY CantonBETWEEN Now

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>16'</u>	<u>Relocated</u>		
MAIN TO PROP. LINE					<u>6/16/98</u>	
PROP. LINE TO BLDG.						


ENTERS: 804BRANCHED INTO: 0TAP SIZE: 3/4 Ser.PRESSURE 60 PSI

INCHES W.C

LOCATION

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY EPMAIN-SIZE 3/4 C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1992DEPTH: 2 FT IN LOCATION"A" P/S READING PTOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY