

LOCATION 910 E. DavidsonCITY GASTONIABETWEEN Center StSTREET & E. Davidson

STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------------|------------|-----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>Plastic</u> | <u>97'</u> | <u>11/26/97</u> | | |
| MAIN TO PROP. LINE | <u>11</u> | <u>11</u> | <u>9'</u> | | | |
| PROP. LINE TO BLDG. | <u>11</u> | <u>11</u> | <u>88'</u> | | | |


ENTERS: 910BRANCHED INTO: —TAP SIZE: 3/8PRESSURE 60 PSI

INCHES W C

LOCATION

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY SEMAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL ✓ PLASTIC — YEAR INSTALLED 1970DEPTH: 2 FT. 0 IN LOCATION"A" P/S READING 1.3TOTAL ANODES 1# — 17# —L.R. # 809138

REMARKS:



| Test Station | | |
|--|--------------|----------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>Riser</u> | <u>Plastic</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY