

LOCATION 202 W. Davidson Ave CITY GASTONIA  
BETWEEN N. York St. STREET & Falls St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>70'</u>			<u>12-5-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>26'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>44'</u>			

ENTERS: Same BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 161' from @ of Falls St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY MD  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 96  
DEPTH: 3 FT. 0 IN. LOCATION Southside of W. Davidson Ave

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>		
	P/S Pipeline Lead - White Existing Main	<u>E</u>		