

LOCATION 211 W. Davidson Ave CITY Gast.  
BETWEEN N. York St. STREET & Falls Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>36'</u>		<u>12-4-96</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>1'</u>	<u>30'</u>			

ENTERS: Same BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 252' from @ of N. York St.


PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY M

MAIN-SIZE 2" C.I.  BARE STEEL  COATED STEEL  PLASTIC ✓ YEAR INSTALLED 96

DEPTH: 3 FT 0 IN LOCATION South Side of Davidson Ave

"A" P/S READING P TOTAL ANODES 1#  T7#  I.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY