

LOCATION 213 W. Davidson Ave CITY Coast.
BETWEEN N. York St. STREET & Falls St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>43'</u>			<u>12-4-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>7'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>36'</u>			

ENTERS: Same BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 215' from @ of N. York St.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY mf

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 96

DEPTH: 3 FT. 0 IN. LOCATION South Side of W. Davidson Ave

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY