

LOCATION 219 W. Davidson Ave CITY Cast.
BETWEEN N. York St. STREET & Falls St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>67'</u>			<u>12-4-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>34'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>33'</u>			

ENTERS: Same BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 104' from @ of N. York St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY my
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC / YEAR INSTALLED 1996
DEPTH: 3 FT. 0 IN LOCATION NORTH SIDE of W. Davidson Ave

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY