

LOCATION 309 W. Davidson Ave CITY Cast.  
BETWEEN N. York St. STREET & Hwy 321 (North) STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>67'</u>		<u>11 - 25</u>	<u>96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>31'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>36'</u>			

ENTERS: Same BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 211' from @ of N. York St.

PRESSURE TEST: @ 100 PSI FOR 44 HRS BY ml  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 96  
DEPTH: 3 FT 0 IN LOCATION NORTH SIDE of W. Davidson Ave

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY