

LOCATION 312 W. DAVIDSON Ave CITY Cast.
BETWEEN Hwy 321 NORTH STREET & N. York St. STREET


| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|-------------|-----------|------------|-----------|---------------|-----------|
| MAIN TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>33'</u> | | <u>11-26-</u> | <u>96</u> |
| MAIN TO PROP. LINE | <u>1"</u> | <u>1"</u> | <u>3'</u> | | | |
| PROP. LINE TO BLDG. | <u>1"</u> | <u>1"</u> | <u>30'</u> | | | |

ENTERS: Same BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 271' ' from @ of W. Davidson Ave

PRESSURE TEST. @ 100 PSI FOR 44 HRS BY TM
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996
DEPTH: 3 FT 0 IN LOCATION North side of W. Davidson Ave.

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

|  | Test Station | | | ENG. DEPT. USE ONLY |
|---|--|----------|-------|---------------------|
| | Reading & Location | Lead | Volts | |
| | P/S Pipeline Lead - Red New Service | S | | |
| | P/S Pipeline Lead - White Existing Main | E | | |