

LOCATION 405 W. Davidson Ave CITY Cast
BETWEEN Hwy 321 STREET & N. York St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>117'</u>		<u>11-26-</u>	<u>96</u>
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>31"</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>86'</u>			

ENTERS: Same BRANCHED INTO:
TAP SIZE. 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 374' from @ of W. Davidson Ave

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY mf
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996
DEPTH 3 FT 0 IN. LOCATION North Side of W. Davidson Ave.

"A" P/S READING P TOTAL ANODES 1# 17# L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY