

LOCATION 814 W. Davidson CITY Easton

BETWEEN N. Weldon STREET & N. Weldon STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>105</u>	<u>6-13-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>25</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>80</u>			

ENTERS: 814 BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Wide House


PRESSURE TEST: @ 100 psi For 14 Hrs. By Bent

MAIN-SIZE 2 C.I. _____ BARE STEEL ☒ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1957

DEPTH: 1 1/4 Ft. 6 In. LOCATION 20' Sept

"A" P/S READING .30 TOTAL ANODES 1* _____ 17* 1 L.R. # 00240153

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY