

LOCATION 814 W Davidson Ave CITY GASTONIA
BETWEEN N Highland STREET & N weldon STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>D</u>	<u>105' EXIST</u>	<u>12-14-96</u>		
MAIN TO PROP. LINE			<u>3' New</u>			
PROP. LINE TO BLDG.						

ENTERS: 814 BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 21' south of

W Davidson


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M Paul

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL X PLASTIC _____ YEAR INSTALLED 96

DEPTH: 3 FT. 0 IN. LOCATION 393' W OF N Highland

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P-RISK</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY