

LOCATION 821 & 823 W. DAVIDSON CITY GAST.

BETWEEN HIGHLAND STREET & WELDON STREET

	SIZE	TYPE	823 LENGTH	821 LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	63'	34'		7-17	96
MAIN TO PROP. LINE	"	"	3'	0			
PROP. LINE TO BLDG.	"	"	60'	34			

ENTERS: 823 BRANCHED INTO: 821

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION E. of 823
W. of 821


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY GK

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 96

DEPTH: 3 FT. IN. LOCATION S. of W. DAVIDSON

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>7</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY