

LOCATION 1134 Apts 1,2,3 W. Davidson Ave CITY GASTONIA
BETWEEN OAKWOOD STREET & GLENN STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>CTW</u>	<u>140' ^{EX. M} 3/4 CTW</u>	<u>TIED OVER</u>		
MAIN TO PROP. LINE			<u>34' NEW 3/4</u>	<u>12-14-90</u>		
PROP. LINE TO BLDG.			<u>174 TOTAL</u>			

ENTERS: 1134 BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 1017' W OF

RANSOM
PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M Parker
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 96
DEPTH: 3 FT. 0 IN. LOCATION 20' N OF W Davidson

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>1.3</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY

Chw
Pistes