

LOCATION 1319 W. DAVIDSON AVE CITY GASTONIA
BETWEEN GLENN STREET & MAUNEY STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>98'</u>		<u>8-6-96</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>93'</u>			

ENTERS: 1319 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION W. OF 1319


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY GK

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC - YEAR INSTALLED 96

DEPTH: 3 FT. IN. LOCATION S. of W. Davidson

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY