

LOCATION 1320 W. DAVIDSON AVE CITY CAST  
BETWEEN DAKWOOD STREET & RAVISON STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>D</u>	<u>134'</u>		<u>9-23-</u>	<u>96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>30'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>104'</u>			

ENTERS: 1320 BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI  INCHES W.C. LOCATION W. of 1320

PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY GK  
MAIN-SIZE 4" C.I.  BARE STEEL  COATED STEEL  PLASTIC / YEAR INSTALLED 96  
DEPTH: 3 FT. IN.  LOCATION W. side of DAKWOOD

"A" P/S READING D TOTAL ANODES 1#  17#  L.R. #

REMARKS:

	Test Station	
	Reading & Location	Volts
	P/S Pipeline Lead - Red New Service	<u>S</u>
	P/S Pipeline Lead - White Existing Main	<u>E</u>

ENG. DEPT. USE ONLY