

LOCATION 1525 W. Davidson CITY GASTONIA  
BETWEEN Bradley STREET & Rhine STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>D</u>	<u>24'</u>		<u>Relocated</u>	
MAIN TO PROP. LINE					<u>4-10-96</u>	
PROP. LINE TO BLDG.						


ENTERS: 1525 BRANCHED INTO: 0  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_

PRESSURE TEST: @ 105 PSI FOR 1/4 HRS. BY E.P.  
MAIN SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED \_\_\_\_\_

DEPTH: 2 FT 6 IN LOCATION \_\_\_\_\_

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 L.R. # \_\_\_\_\_

REMARKS.  
Tracker wire bonded to ext c/w pipe

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>1.3</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		