

LOCATION 714 A Davis Heights CITY Cincinnati
BETWEEN Hwy 321 South STREET & - STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>GND</u>	<u>10'</u>	<u>Relocated</u>	<u>3-10-97</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 714 BRANCHED INTO: 714A
TAP SIZE: 3/4 sec. PRESSURE 60 PSI _____ INCHES W.C. LOCATION


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY E. Baum

MAIN SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 1 FT. 6 IN. LOCATION

"A" P/S READING 1.6 TOTAL ANODES 1# 1 17# 0 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>1.6</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY