

LOCATION 109 DAVIS PARK Rd CITY GASTONIA  
BETWEEN S. York Rd. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	48'		9. 6. 94	
MAIN TO PROP. LINE	"	"	5'			
PROP. LINE TO BLDG.	"	"	43'			

ENTERS: 109 DAVIS PK Rd BRANCHED INTO:  
TAP SIZE: 1/2" PRESSURE 60 P.S.I. INCHES W.C. LOCATION W. Side of house


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By GK

MAIN-SIZE 4" C.I. — BARE STEEL — COATED STEEL — PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 3 Ft. In. LOCATION S. Side of DAVIS Park Rd

"A" P/S READING N/A TOTAL ANODES 1# 17 # 17 L.R. #       

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	N/A
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY