

LOCATION 228 Davis Park Rd. CITY Bastonia  
BETWEEN Crawford St. STREET & 321 - South STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>53'</u>	<u>6-28-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>13'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>40'</u>			

ENTERS: 228 BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 107' W of C of Davis Park Rd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1968

DEPTH: 3 Ft. 0 In. LOCATION 12' E of C of Crawford St.

"A" P/S READING .90 TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # 276097

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY