

LOCATION S26 Davis Park Rd CITY CANTONIA

BETWEEN Weston ST STREET & Lamar ST STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>103'</u>	<u>5-9-95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>30'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>73'</u>			

ENTERS: S26 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 46' E. of center

of Weston ST


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFELN

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1960

DEPTH: 3 Ft. 0 In. LOCATION 12' S. of center of Davis Park Rd

"A" P/S READING .85 TOTAL ANODES 1* 0 17* 0 L.R. # 722989

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		