

LOCATION 723 Davis Park Rd CITY Gastonia
BETWEEN Curtis STREET & Randy STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>172</u>	<u>8-4-98</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>1</u>	<u>8'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>164'</u>			

ENTERS: 723

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 13' S. of C of Davis Park


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SP

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1963

DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING .80 TOTAL ANODES 1# _____ 17# 1 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY