

LOCATION 1730 Davis Park Rd CITY Gastonia  
BETWEEN Garland STREET & Findlay STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>82</u>	<u>3-14-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>10</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>72</u>			

ENTERS: 1730 BRANCHED INTO:  
TAP SIZE: 3/8 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 14' E OF Davis Park

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By M Parker  
MAIN-SIZE 6" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL / PLASTIC \_\_\_\_\_ YEAR INSTALLED 1961  
DEPTH: 3 Ft. 0 In. LOCATION 404' south of Garland

"A" P/S READING .9 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # 118872

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY