

LOCATION 1814 DAVIS PK. Rd CITY Gaetonia
BETWEEN Findlay STREET & GARLAND STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>50'</u>	<u>12-13-89</u>		
MAIN TO PROP LINE	<u>11</u>	<u>1</u>	<u>6'</u>			
PROP LINE TO BLDG	<u>11</u>	<u>4</u>	<u>44'</u>			

ENTERS 1814 BRANCHED INTO -
TAP SIZE 1/2 PRESSURE _____ PSI _____ INCHES WC LOCATION 15' E. of cop

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SP Davis PK

MAIN-SIZE 6" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1961

DEPTH 3 FT 0 IN LOCATION _____

"A" P/S READING 1.00 TOTAL ANODES 1# 17 LR # _____

REMARKS _____

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

