

LOCATION 2404 Davis Park Rd CITY Lubbock
BETWEEN Shrover STREET & Richmond Dr STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>110</u>	<u>B-8-54</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>12</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>98</u>			

ENTERS: 2404 BRANCHED INTO:
TAP SIZE: 3/8 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION East of house

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Bonett
MAIN-SIZE 6 C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1961
DEPTH: 2 Ft. 6 In. LOCATION 13' E of rd

"A" P/S READING .80 TOTAL ANODES 1* 17 * 1 L.R. # 0039826

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY