

LOCATION 2723 Davis Park Rd CITY Creston  
 BETWEEN Cedar Oak Cir STREET & Penny Park Dr. STREET

Service

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	38'	5-9-03		
MAIN TO PROP LINE	3/8"	P	14'	"		
PROP LINE TO BLDG	5/8"	P	24'	"		

Service


ENTERS 2723 BRANCHED INTO 2719  
 TAP SIZE 1/2" PRESSURE 60 PSI INCHES W C LOCATION 376' west of

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY N. Woody  
 MAIN SIZE 3/4" C I COATED STEEL ☒ PLASTIC YEAR INSTALLED 1967

DEPTH 2' FT 0" IN LOCATION 92' south of center of Davis Park Rd.

"A" P/S READING .98 TOTAL ANODES 1# 0 17# 0 LR # 00001520

REMARKS New Plastic service  
(split)



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	river