

LOCATION 911 E. Davis CITY Gastonia
 BETWEEN Belvedere STREET & Church STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>51'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>10'</u>			<u>2-5-86</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>41'</u>			

ENTERS: 911 BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 20 P.S.I. _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 psi For 1 1/2 Hrs. By ED

MAIN-SIZE 1 1/4 C.I. _____ BARE STEEL ☒ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1941

DEPTH: 2 Ft. 6 In. LOCATION _____

"A" P/S READING .6 TOTAL ANODES 1* 17* 1 L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY