

LOCATION 2137 DAWN SHIRE DR.CITY GASTONIABETWEEN RUDD DR.STREET & SHANNON DR.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plast.</u>	<u>98'</u>	<u>11-4-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plast.</u>	<u>12'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plast.</u>	<u>86'</u>			


ENTERS: 2137 DAWN SHIRE DR.BRANCHED INTO: 0TAP SIZE: 3/8PRESSURE 60

P.S.I.

INCHES W.C.

LOCATION 155' N of CoF SHANNON DR.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By B.S.MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1979DEPTH: 3 Ft. 0 In.LOCATION 15' W of CoF DAWN SHIRE DR."A" P/S READING 0.9TOTAL ANODES 1# 17# L.R. # 00495175

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY