

LOCATION 4303 DawnwoodCITY GastoniaBETWEEN KnightwoodSTREET & Frostwood

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	114'	1-26-94		
MAIN TO PROP. LINE	3/4	P	40'			
PROP. LINE TO BLDG.	3/4	P	74'			


ENTERS: 4303BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60

P.S.I.

INCHES W.C.

LOCATION W. Side of 4303PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BCMAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1990DEPTH: 3 Ft. In. LOCATION 17' N of C of Dawnwood"A" P/S READING Plastic TOTAL ANODES 1* 17* L.R. # 24520

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY