

LOCATION 4308 Dawnwood Dr. CITY Gastonia

BETWEEN Troutwood Dr STREET & Knightwood Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>74'</u>	<u>6-11-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>31'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>43'</u>			

ENTERS: 4308 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 91' S. of center of

Dawnwood Dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. H. H. H. H.

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 18' W. of center of Knightwood Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 388158

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY