

LOCATION 4413 Dawnwood Dr. CITY Gastonia

BETWEEN Knightwood Dr STREET & Conchwood Lw. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG		P	84'	6-13-01		
MAIN TO PROP LINE		P	10'			
PROP LINE TO BLDG		P	84'			

ENTERS 4413 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 420' W. of center of Knightwood Dr.


PRESSURE TEST @ 100 PSI FOR 14 HRS BY S.H.

MAIN-SIZE 4" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1991

DEPTH 3 FT 0 IN LOCATION 17' N. of center of Dawnwood Dr.

"A" P/S READING P TOTAL ANODES 1# 8 17# 0 LR # A0451334

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	