

LOCATION

4423 DAWNWOOD DR

CITY

GASTON, GA

BETWEEN

COACHWOOD DR

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	75'	2-29-96		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	65'			

ENTERS:

4423

BRANCHED INTO:

TAP SIZE:

1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

217' E. of center of

COACHWOOD DR

PRESSURE TEST: @

100

psi

For

1/4

Hrs.

By

S. HUFFSTETH

MAIN-SIZE

4"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

☒

YEAR INSTALLED

1991

DEPTH:

3 Ft.

0 In.

LOCATION

18' N. of center of DAWNWOOD DR.

"A" P/S READING

P

TOTAL ANODES

1#

0


17#

0

L.R. #

95593

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	