

LOCATION 4429 Dawnwood Dr. CITY Gastonia, NC
BETWEEN Coachwood Ln. STREET & Frostwood Ln. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	68'	6-25-01		
MAIN TO PROP LINE	3/4"	P	6'	"		
PROP LINE TO BLDG	3/4"	P	62'	"		

ENTERS 4429 BRANCHED INTO Ø
TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION 111' East


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woolf
center of Coachwood Ln.

MAIN-SIZE 4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1991

DEPTH 3' FT 0" IN LOCATION 18' north of center of Dawnwood Ln.

"A" P/S READING 0.114 TOTAL ANODES 1# Ø 17# Ø LR # 00471187

REMARKS New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	E	<u>rigid</u>