

LOCATION 3234 Deerwood Dr

CITY GastoniaBETWEEN Gordner Park Dr.STREET & Imperial Dr

STREET

|                     | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG.       | 3/4  | P    | 152'   | 11-27-95  |         |         |
| MAIN TO PROP. LINE  | 1"   | 11   | 40'    |           |         |         |
| PROP. LINE TO BLDG. | 1"   | 11   | 112'   |           |         |         |

ENTERS: 3234

BRANCHED INTO: —

TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 18' S. of C of

Deerwood Dr

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By EP

MAIN-SIZE 2"

C.I. —

BARE STEEL —

COATED STEEL ☒

PLASTIC —

YEAR INSTALLED 1961

DEPTH: 3 Ft. 0 In.


LOCATION

"A" P/S READING 1.400

TOTAL ANODES 1# — 17# —

L.R. #

REMARKS:



| Test Station                               |           |          |
|--|-----------|----------|
| Reading & Location                         | Lead      | Volts    |
| P/S Pipeline Lead - Red<br>New Service     | <u>ER</u> | <u>P</u> |
| P/S Pipeline Lead - White<br>Existing Main | <u>E</u>  |          |

ENG. DEPT. USE ONLY