

LOCATION 3310 Deerwood Dr. CITY GASTOWIA
BETWEEN Imperial Dr. STREET & Gardner Park Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>144'</u>	<u>8-6-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>42'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>102'</u>			

ENTERS: 3310

BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 790' E of 1st of Imperial Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1961

DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 I.R. # 398638

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Riser</u>

ENG. DEPT. USE ONLY