

LOCATION 2408 Denise dr

CITY Gaslonie

BETWEEN woodBRIAR

STREET & WINDSONG

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	116'	1-14-99		
MAIN TO PROP. LINE	11	11	40'			
PROP. LINE TO BLDG.	11	11	76'			

ENTERS: 2408

BRANCHED INTO:

TAP SIZE: 1/2	PRESSURE _____ PSI	INCHES W.C.	LOCATION 15' W. of cor Denise
---------------	--------------------	-------------	----------------------------------


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JP

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1999

DEPTH: 3 FT. 0 IN. LOCATION

"A" P/S READING 1.40 TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY