

LOCATION 500 Derby Ct CITY Gastonia
BETWEEN Bridle Path Tr STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Cu</u>	<u>75'</u>	<u>4/23/94</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>Plastic</u>	<u>2'</u>			
PROP. LINE TO BLDG.						

ENTERS: 500 BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 P.S.I. INCHES W.C. LOCATION West side of 500

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1992
DEPTH: 3 Ft. 0 In. LOCATION North side of Derby Ct

"A" P/S READING 1.50 TOTAL ANODES 1# 1 17# 0 L.R. #

REMARKS: Tied over 75' of ex 3/4" Cu service
to new main, ex 3/4" LAs Dresser Banded



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>1.50</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY